

Water Department 562 Winterbrook Road, Campton, NH 03223 Phone: (603) 726-3082 | Fax: (603) 726-8611 www.waterville-estatesnh.gov

Summary of Terms and Conditions for New Connections

This is not meant to be a complete or comprehensive list of the terms and conditions for new water connections within the Waterville Estates Village District

New Connections

- No new connections shall be made until the required application is submitted and approved by the WEVD Commissioners, any applicable fees paid, and necessary inspections have been completed (pg. 8-9, sec. 5, sec. 7)
- A \$1,000 new connection fee is due at the time the permit is issued
- Of the new connect fee, \$250 is a non-refundable administrative service charge
- Permits are only valid for 60 days and are nontransferable

Metering

- All new connections will be required to be metered and water service will not be provided until a meter is installed (pg. 9, sec. 7)
- Meters shall be provided within 15 days of the receipt of request for a meter following the inspection of service lines has been approved by a District representative (pg. 9, sec. 7)

Service Lines

- Services lines from the curb stop to the building are the sole responsibility of the owner to maintain (pg. 10, sec. 9, b)
- The minimum diameter for service lines to a single-family residence is 1 inch (pg. 10, sec. 9, c)
- All service lines must conform to AWWA Standards, ANR Water Supply Division rules and technical standards, New Hampshire Statutes, and District standards (pg. 10, sec. 9, c)
- When rate flow will exceed 15 gallons per minute the District may require services lines to be greater than 1 in. in diameter (pg. 10, sec. 9, c)

Extending Service

- The application process and requirements for the extension of service mains can be found on page 16, section 32 "Water Main Extension, Plan Approval, Construction"
- All cost for extending water service to an individual property is the responsibility of the property owner (pg. 9, sec. 7)
- "New service or extension of mains shall not be constructed during the period November 15 to April 15 without prior cold weather construction approval of the District. The owner may be assessed an additional charge as part of the connection fee to cover the additional expense incurred as a result of cold weather construction." (pg. 11, sec. 12)



Water Department 562 Winterbrook Road, Campton, NH 03223 Phone: (603) 726-3082 | Fax: (603) 726-8611 www.waterville-estatesnh.gov

Water Hookup Permit Application

Name of Owner on Record:				
Telephone:	Email:			-
Is there a designated representative other	than the owner? []	Yes [] No		
Name of Representative:Contact Address:				
Street	City	State	Zip	-
Telephone:	Email:			-
Attachments (please check all that apply [] NH DES approved septic desi [] WEA building permit [] Site plan				
When issued, permits are valid for 60 da limited to the \$1,000 new connection feed must have meters installed prior to connection by the property owner. Please visit y Request Form to acquire a meter.	e, are due upon receip ection. Meters and ko	t of an approved per rnerhorns are to be	ermit. All new co	onstruction the District at
By signing below, I acknowledge that I I outlined in the Waterville Estates Village all applicable fees upon receipt of my ap to me or valid until all applicable fees are	e District Water Ordin proved permit. I unde	nance adopted in A	ugust 2021. I als	so agree to pay
Signature		Date		-

FOR OFFICE USE ONLY

Date application submitted:	Initials:
Date of site visit:	
Attendees:	
	Approved [] Approved subject to the following conditions:
Date Issued:	Permit No.:
Expiration Date:	(Year - # of permit e.g., 2020-XX)
Name:	
Title:	
Name:	
Title:	
Name:	
Title:	